

Addendum No. 1

Careful note of the Addendum shall be taken by all parties of interest so that the proper allowances may be made in strict accordance with the Addendum.

Bidder shall acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

Bid Invitation Document Changes: The following changes, omissions, and/or additions to the Request for Proposal/ and or Invitation to Bid shall apply to proposals made and all other conditions shall remain the same.

Submitted Questions:

1. Are all 3 portables to be set on one campus? **Yes on one campus and one location side by side.**
2. Might site plan(s) be available to review access and placement on campus? **Attached, this work area is outlined in yellow.**
3. Is a specific handing necessary for the exterior door? (while facing 24' elevation, door to be at right or left) **Left swing preferred due to prevailing winds.**
4. Regarding floor finish, is 24"x 24" carpet tiles acceptable? **Yes, Acceptable.**

